PRACTICAL SIGNIFICANCE OF COMBINED METHODS FOR THE TREATMENT OF ARTESIAN WATER

Shakhboz Esanmurodov

Assistant Lecturer, Tashkent State Transport University, Tashkent, Uzbekistan.

E-mail: shakhbozjonesanmurodov@gmail.com

Gulchekhra Rikhsihojaeva

Associate Professor, Tashkent State Transport University, Tashkent, Uzbekistan.

E-mail: gulchexrarr@gmail.com

Abstract. This paper considers the combination of treatment stages to reduce mineral and organic impurities that may occur in artesian water. The functions of mechanical filtration, coagulation, aeration, ion exchange, activated-carbon adsorption and disinfection are discussed. It is emphasized that the treatment scheme should be selected on the basis of an initial laboratory analysis of the water.

Keywords: artesian water, water treatment, mineralization, hardness, cation-exchange resin, adsorption, activated carbon, aeration, disinfection.

Providing safe drinking water is one of the principal tasks of water-supply systems. Because artesian water is drawn from underground formations, it may be relatively protected from direct surface contamination. However, its chemical composition depends on the geological formations through which it passes, mineral solubility, well depth and local hydrogeological conditions. Clear appearance alone is therefore insufficient to confirm that water is safe; laboratory testing is required.

Artesian water may contain elevated concentrations of calcium and magnesium salts, which increase hardness. Iron and manganese can affect colour and taste and may form deposits after water is exposed to air. Dissolved gases and organic compounds may also be present in some sources. Since a single treatment method may not adequately remove all these constituents, treatment stages should be combined according to the actual water quality.

The aim of this paper is to summarize the functions of major water-treatment methods described in the supplied literature, compare their capabilities and limitations, and explain the practical value of an integrated treatment approach. The discussion is based on three manuscripts supplied by the user concerning ion-exchange sorbents, removal of mineral salts and microcomponents, and treatment of organic-mineral impurities in artesian water. No new laboratory experiments or original measurement results are claimed in this paper.

1. Preliminary and mechanical treatment. Sedimentation and filtration reduce sand, suspended solids, silt and other particles. These processes do not remove dissolved calcium, magnesium or other salts completely, but they can reduce the particulate load reaching downstream equipment. Where fine dispersed or colloidal particles are present, coagulation and flocculation help combine them into larger aggregates, which can then be removed by sedimentation or filtration [2, 3].

2. Iron removal and aeration. The supplied literature notes that water containing iron may initially appear clear but become yellowish after standing, with deposits forming over time. Depending on the water composition, iron removal may involve aeration, oxidation with suitable reagents, or specialized filter media. The appropriate option depends on the form of iron, pH, reagent dose and operating conditions. Filtration may be required after oxidation to remove the particles formed [2].

3. Hardness reduction and ion exchange. Water hardness is primarily associated with calcium and magnesium ions. Ion-exchange materials retain selected ions and release counter-ions from the resin. Sodium-form cation-exchange resins are used for softening; their performance depends on exchange capacity, water composition and regeneration conditions. The supplied literature discusses materials such as KU-2-8 and Amberlite IR-120 and their sorption of certain metal ions [1]. However, findings on heavy-metal sorption should not be treated as proof that a resin is automatically suitable for drinking-water treatment. Specific testing and compliance with relevant sanitary requirements are necessary. Ion exchange alone also does not remove all microorganisms or organic compounds.

4. Adsorption of organic impurities. The porous structure of activated carbon allows it to adsorb certain organic compounds. The supplied manuscript describes treatment schemes using powdered activated carbon at selected stages and granular activated carbon in filters. These materials may help reduce some compounds responsible for taste and odour. Performance depends on the contaminant, contact time, water composition and the condition of the adsorbent. A suitable replacement or regeneration schedule is therefore needed [3].

5. Disinfection and final quality control. Chlorination, ozonation and ultraviolet irradiation are used to reduce microbiological risks. They are not interchangeable in every situation; selection depends on water quality, plant design and operating requirements. Disinfection does not replace mechanical filtration or ion exchange. Microbiological and chemical indicators should be checked in the treated water, with residual reagents and potential oxidation by-products monitored where relevant.

Figure 1. Indicative sequence for artesian-water treatment

Note: This is a general conceptual scheme. Not every stage is mandatory for every source; selection depends on laboratory results.

Table 1. Functions and limitations of water-treatment methods

Treatment method	**Main function**	**Limitation or control point**
Mechanical filtration	Removes suspended particles	Does not fully remove dissolved salts
Coagulation and sedimentation	Facilitates removal of colloids	Reagent dose and pH must be controlled
Aeration/oxidation	Can assist removal of some gases and iron	Depends on water composition and conditions

Ion exchange	Reduces calcium and magnesium ions	Resin capacity and regeneration
Activated carbon	Reduces some organics, taste and odour	Adsorbent service life and replacement
Disinfection	Reduces microbiological risk	Dose, contact time and monitoring

The supplied sources indicate that the coordination of treatment stages is important. Removing suspended particles early can reduce the load on adsorbents and ion-exchange beds. Where hardness is high, ion exchange or another softening process may be considered; where organic compounds or taste-and-odour problems are present, activated carbon may be useful. Elevated iron or manganese may require oxidation followed by filtration.

Nevertheless, adding every available treatment stage without assessing the source is neither technically nor economically justified. Unnecessary stages may increase energy use, chemical consumption, maintenance needs and waste-management costs. Water should first be analysed in a laboratory, after which methods should be selected for the contaminants of concern. The treated water should then be monitored periodically to confirm that the required quality is maintained.

Conclusion

Combining treatment methods can reduce different types of impurities through complementary mechanisms. Mechanical filtration removes suspended particles; coagulation facilitates the removal of colloids; aeration and oxidation may assist in removing certain gases and iron; ion exchange is used to reduce hardness ions; and activated carbon adsorbs selected organic compounds. Disinfection is a separate barrier intended to reduce microbiological risk. The treatment scheme should be based on laboratory analysis of the source water, appropriate operation of the equipment and verification of the final water quality. Further practical research could compare water samples before and after individual treatment stages, evaluate removal efficiency and assess operating costs.

References

[1] “Current State of Ion-Exchange Sorbents and Their Application in the Treatment of Mineralized Artesian Waters.” Manuscript supplied by the user.

[2] Rikhsihojaeva, G. R., and Esanmurodov, Sh. V. “Method for Treating Mineralized Artesian Waters to Remove Mineral Salts and Microcomponents.” Manuscript supplied by the user.

[3] “Study of the Technology for Treating Mineralized Artesian Waters to Remove Mineral Salts.” Manuscript supplied by the user.